

Addendum #3
Project #2695
BC Duck Creek Highway Shop Roof Upgrades
Highway
August 27, 2024
Request for Bid

See original specification packet for addresses

THIS ADDENDUM IS ISSUED TO MODIFY, EXPLAIN OR CORRECT THE ORIGINAL DRAWINGS AND SPECIFICATIONS AND IS HEREBY MADE PART OF THE CONTRACT DOCUMENTS. THIS ADDENDUM MUST BE ACKNOWLEDGED ON THE ADDENDUM RECEIPT SCHEDULE, WHICH WAS INCLUDED IN THE ORIGINAL DOCUMENT PACKAGE.

Vendors are required to read entire addendum to determine requirements affecting their contract.

Addendum #3

This addendum is for the following:

- To provide info for project changes and clarifications
- To provide information for the bid opening

Project Changes:

- Sheet A-202; Change keynote 9 on plan at south abandoned beam to keynote 9A. Provide new keynote 9A . “Abandoned raised beam supporting roof ladder to remain in place.”
- Sheets A-201 and A—202; Add keynote 2A, “Air Conditioning units not currently secured to rooftop to have curb provided and be secured to rooftop.”
- Sheet A-301. Detail 1; Remove term “hot-mopped” from notes, replace with “fully adhered”.
- Copper flashing to be removed from face of parapet. Copper thru-wall flashing to remain. See attached detail 1A/A301.

Project Clarifications:

- Estimated completion schedule for project phases is to be submitted with Bid Proposal. Full project Substantial Completion by May 30, 2025
- If a core sample of roof system is completed, It will be shared by addendum prior to bid opening.

Bid Opening Information:

Microsoft Teams [Need help?](#)

[Join the meeting now](#)

Meeting ID: 221 308 758 797

Passcode: BRBk5r

Dial in by phone

872-256-4158


Phone conference ID: 515 422 517

Bid opening will start at 11:00am. It is recommended to call in or log into the meeting at least 5 minutes prior to start. Bid prices will be read aloud twice for each vendor submitting a bid.

Reminder: All bids must either be mailed, or hand delivered and received by 11:00am CST on Thursday, September 12, 2024. Hand delivered or mailed bids are go to the County Clerk, 305 E Walnut Street, Room 120, Green Bay, WI 54301. Bids received after 11:00am will not be opened.

BID DUE DATE

9/12/24 BY 11:00 A.M. CST



1a **PARAPET FLASHING
DETAIL**