

Addendum #3
Project #2706
Replacement of Chiller at Sophie Beaumont
Facilities
October 16, 2024
Request for Bid
See original specification packet for addresses

THIS ADDENDUM IS ISSUED TO MODIFY, EXPLAIN OR CORRECT THE ORIGINAL DRAWINGS AND SPECIFICATIONS AND IS HEREBY MADE PART OF THE CONTRACT DOCUMENTS. THIS ADDENDUM MUST BE ACKNOWLEDGED ON THE ADDENDUM RECEIPT SCHEDULE, WHICH WAS INCLUDED IN THE ORIGINAL DOCUMENT PACKAGE.

Vendors are required to read entire addendum to determine requirements affecting their contract.

Addendum #3

This addendum is for the following:

- To answer questions received for project
- To provide information for the bid opening

Questions: (answers in red font)

- 1) Plan calls for (2) 2” conduits to feed new chiller, is it permitted to reuse the existing (2) 3” conduits as our raceway from the basement to the roof?
 - a. It is permitted to use the existing (2) 3” conduits.
- 2) Is it permitted to reuse the existing disconnect on the roof and existing disconnect in the basement for the chiller?
 - a. It is permitted to reuse the existing disconnect in the basement with the specified wire. The disconnect on the roof is to be replaced.
- 3) For the hydronic pump connectors is Twin City Hose acceptable manufacturer?
 - a. Yes, Twin City Hose is an acceptable manufacturer.

Bid Opening Information:

Microsoft Teams [Need help?](#)

Join the meeting now

Meeting ID: 254 303 984 100

Passcode: ENcZeI

Dial in by phone

872-256-4158

Phone conference ID: 546 388 366

BID DUE DATE
10/22/24 BY 11:00 A.M. CST