

**Addendum #2**  
**Project #2776**  
**Furnace and A/C Replacement at Airport**  
**Airport**  
**November 14, 2025**  
**Request for Bid**

**See original specification packet for addresses**

THIS ADDENDUM IS ISSUED TO MODIFY, EXPLAIN OR CORRECT THE ORIGINAL DRAWINGS AND SPECIFICATIONS AND IS HEREBY MADE PART OF THE CONTRACT DOCUMENTS. THIS ADDENDUM MUST BE ACKNOWLEDGED ON THE ADDENDUM RECEIPT SCHEDULE, WHICH WAS INCLUDED IN THE ORIGINAL DOCUMENT PACKAGE.

Vendors are required to read entire addendum to determine requirements affecting their contract.

**Addendum #2**

This addendum is for the following:

- To answer questions received
- To provide information for the bid opening

**Questions:**

1. Are the (2) new furnaces and existing 3<sup>rd</sup> furnace supposed to have functional economizer controls? Existing economizer control panel appears to be abandoned.  
**No, these can be removed or bypassed at this time.**
2. Do we need to include low ambient controls for the new condensing units?  
**No**
3. Do we need to replace or reuse the existing disconnects for the (2) new condensing units?  
**Re use.**
4. Is there a minimum furnace efficiency % requirement for the new furnaces?  
**Preferably high efficiency rating of 90% or more.**

**Bid Opening Information:**

**Microsoft Teams** [Need help?](#)

**[Join the meeting now](#)**

Meeting ID: 274 439 817 372 9

Passcode: C7oJ6g4x

---

**Dial in by phone**

872-256-4158 United States, Chicago

Phone conference ID: 910 019 582#

Bid opening will start at 11:00am. It is recommended to log into the meeting at least 5 minutes prior to start. Bid prices will be read aloud twice for each vendor submitting a bid.

**Reminder: All bids must either be mailed or hand delivered and received by 11:00am CST on Wednesday, November 19, 2025. Hand delivered or mailed bids are go to the County Clerk, 305 E Walnut Street, Room 120, Green Bay, WI 54301. Bids received after 11:00am will not be opened.**

**BID DUE DATE**

**11/19/25 BY 11:00 A.M. CST**